

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 7125-1496:104

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Firecom Inc., 39-27 59th Street, NY 11377
Contact: Howard Kogen (718) 899-6100

DESIGN: Models FVA3 and FVA4 series, employing light modules RC24D, RF24D (110cd); RA24D, RD24D (15cd); RB24D, RE24D (75cd) strobe lights for the hearing impaired and Model FSSM sync module. Models RD24D, RE24D and RF24D are synchronized strobes and must be used with Model FSSM sync module. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/strobe rating, and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired when used in conjunction with separately listed compatible audible devices and fire alarm control units. For wall mounting and indoor use only.

XLF: 7125-0553:103

12-17-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 22, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy
Program Manager